



Drinking Water Results Report

Order ID: 8105424

EHC Associates, Inc.
2502 Horseshoe Road
Lancaster, PA 17601

Project: Wilson SD

Attn: Barb King

PWSID:

Sample Number: 8105424-01	Site: Water Fountain - A-500 Hall	Sample ID: Wilson SD High School - Upper House
Collector: MA	Collect Date: 10/29/2018 8:02 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:22	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-02	Site: Water Fountain - E-400 Hall	Sample ID: Wilson SD High School - Upper House
Collector: MA	Collect Date: 10/29/2018 8:06 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:24	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-03	Site: Sink - Nurse's Office	Sample ID: Wilson SD High School - Upper House
Collector: MA	Collect Date: 10/29/2018 8:08 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:26	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-04	Site: Sink- Cafeteria	Sample ID: Wilson SD High School - Upper House
Collector: MA	Collect Date: 10/29/2018 8:11 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:28	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-05	Site: Stadium Concession Sink	Sample ID: Wilson SD High School - Lower House
Collector: MA	Collect Date: 10/29/2018 8:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:31	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/12/2018 11:43 am
STL_DW_Results Revision #1.7

8105424
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 8105424-06 Site: Sink- Locker Room Sample ID: Wilson SD High School - Lower House
Collector: MA Collect Date: 10/29/2018 8:25 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:33	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-07 Site: Sink - Kitchen Sample ID: Wilson SD High School - Lower House
Collector: MA Collect Date: 10/29/2018 8:29 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:35	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-08 Site: Sink- Outside Main Office Sample ID: Wilson SD High School - Lower House
Collector: MA Collect Date: 10/29/2018 8:31 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:37	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-09 Site: Sink - Kitchen Sample ID: Wilson SD - Berkshire Heights
Collector: MA Collect Date: 10/29/2018 8:48 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.003	mg/L	EPA 200.8	0.015	Pass	0.001	11/01/18	RPV	11/02/18 19:43	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-10 Site: Fountain - Near Rm 4 Sample ID: Wilson SD - Berkshire Heights
Collector: MA Collect Date: 10/29/2018 8:51 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.005	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 15:06	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-11 Site: Sink - Boys bathroom basement Sample ID: Wilson SD - Berkshire Heights
Collector: MA Collect Date: 10/29/2018 8:53 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 15:39	RPV
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-12 Site: Fountain - Main Hallway Sample ID: Wilson SD - Berkshire Heights
Collector: MA Collect Date: 10/29/2018 8:57 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:16 RPV

Sample Number: 8105424-13 Site: Sink - Kitchen Sample ID: Wilson SD- Spring Ridge Elem
Collector: MA Collect Date: 10/29/2018 9:12 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:17 RPV

Sample Number: 8105424-14 Site: Sink - Faculty Room Sample ID: Wilson SD- Spring Ridge Elem
Collector: MA Collect Date: 10/29/2018 9:15 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:19 RPV

Sample Number: 8105424-15 Site: Sink - Room 117 Sample ID: Wilson SD- Spring Ridge Elem
Collector: MA Collect Date: 10/29/2018 9:18 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:21 RPV

Sample Number: 8105424-16 Site: Fountain - Near Nurse Sample ID: Wilson SD- Spring Ridge Elem
Collector: MA Collect Date: 10/29/2018 9:22 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:23 RPV

Sample Number: 8105424-17 Site: Sink - Kitchen Sample ID: Wilson SD - Whitfield Elem
Collector: MA Collect Date: 10/29/2018 9:29 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:25 RPV

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-18

Site: Fountain - Hall @ Main Office

Sample ID: Wilson SD - Whitfield Elem

Collector: MA

Collect Date: 10/29/2018 9:31 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:27 RPV

Sample Number: 8105424-19

Site: Fountain - Hall @ B104

Sample ID: Wilson SD - Whitfield Elem

Collector: MA

Collect Date: 10/29/2018 9:34 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:29 RPV

Sample Number: 8105424-20

Site: Sink - Bathroom @ L120

Sample ID: Wilson SD - Whitfield Elem

Collector: MA

Collect Date: 10/29/2018 9:37 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:31 RPV

Sample Number: 8105424-21

Site: Sink - Transportation bldg

Sample ID: Wilson SD - Southern Middle School

Collector: MA

Collect Date: 10/29/2018 10:06 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:33 RPV

Sample Number: 8105424-22

Site: Sink - Kitchen

Sample ID: Wilson SD - Southern Middle School

Collector: MA

Collect Date: 10/29/2018 10:11 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.002 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:43 RPV

Sample Number: 8105424-23

Site: Fountain - @Gym

Sample ID: Wilson SD - Southern Middle School

Collector: MA

Collect Date: 10/29/2018 10:14 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:45 RPV

Report Generated On: 11/12/2018 11:43 am
STL_DW_Results Revision #1.7

8105424
Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-24	Site: Sink- Boys Bathroom @ 104 LL Commons	Sample ID: Wilson SD - Southern Middle School
Collector: MA	Collect Date: 10/29/2018 10:17 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 15:47	RPV
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-25	Site: Fountain - @ Rm 102	Sample ID: Wilson SD - Cornwall Terrace Elem
Collector: MA	Collect Date: 10/29/2018 10:26 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:10	RPV
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-26	Site: Fountain - @ Rm 111	Sample ID: Wilson SD - Cornwall Terrace Elem
Collector: MA	Collect Date: 10/29/2018 10:29 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:37	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-27	Site: Fountain - @ Rm 132	Sample ID: Wilson SD - Cornwall Terrace Elem
Collector: MA	Collect Date: 10/29/2018 10:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:15	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-28	Site: Sink - Nurse's Office	Sample ID: Wilson SD - Cornwall Terrace Elem
Collector: MA	Collect Date: 10/29/2018 10:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:17	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-29	Site: Sink - Office	Sample ID: Wilson SD- Shiloh Hills Elem
Collector: MA	Collect Date: 10/29/2018 10:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:19	RPV
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-30 Site: Sink - Rm 163 Sample ID: Wilson SD- Shiloh Hills Elem
Collector: MA Collect Date: 10/29/2018 10:57 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:21	RPV
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-31 Site: Sink - Rm101 Sample ID: Wilson SD- Shiloh Hills Elem
Collector: MA Collect Date: 10/29/2018 11:01 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:23	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-32 Site: Sink - Kitchen Sample ID: Wilson SD- Shiloh Hills Elem
Collector: MA Collect Date: 10/29/2018 11:05 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:29	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-33 Site: Sink - Office Bathroom Sample ID: Wilson SD - Green Valley Elem
Collector: MA Collect Date: 10/29/2018 11:23 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:31	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-34 Site: Sink - Rm 159 Sample ID: Wilson SD - Green Valley Elem
Collector: MA Collect Date: 10/29/2018 11:26 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:33	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8105424-35 Site: Sink - Rm 111 Sample ID: Wilson SD - Green Valley Elem
Collector: MA Collect Date: 10/29/2018 11:30 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	11/06/18	AER	11/09/18 14:35	RPV
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-36 Site: Sink - Kitchen Sample ID: Wilson SD - Green Valley Elem
Collector: MA Collect Date: 10/29/2018 11:33 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.007 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:41 RPV

Sample Number: 8105424-37 Site: Sink - Kitchen Sample ID: Wilson SD - West Middle School
Collector: MA Collect Date: 10/29/2018 11:39 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:43 RPV

Sample Number: 8105424-38 Site: Fountain - @ SGI 120 Sample ID: Wilson SD - West Middle School
Collector: MA Collect Date: 10/29/2018 11:41 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:45 RPV

Sample Number: 8105424-39 Site: Sink @ Nurse's Sample ID: Wilson SD - West Middle School
Collector: MA Collect Date: 10/29/2018 11:43 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.003 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:47 RPV

Sample Number: 8105424-40 Site: Fountain @ SGI 138 Sample ID: Wilson SD - West Middle School
Collector: MA Collect Date: 10/29/2018 11:47 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:53 RPV

Sample Number: 8105424-41 Site: Fountain - South End Sample ID: Wilson SD - Lower Heidelber
Collector: MA Collect Date: 10/29/2018 12:08 pm Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.002 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:54 RPV

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8105424-42 Site: Sink - Kitchen Sample ID: Wilson SD - Lower Heidelberg
Collector: MA Collect Date: 10/29/2018 12:11 pm Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.003 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:56 RPV

Sample Number: 8105424-43 Site: Sink - Office Sample ID: Wilson SD - Lower Heidelberg
Collector: MA Collect Date: 10/29/2018 12:13 pm Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 14:58 RPV

Sample Number: 8105424-44 Site: Sink - Janitor's Closet Sample ID: Wilson SD - Lower Heidelberg
Collector: MA Collect Date: 10/29/2018 12:17 pm Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/06/18 AER 11/09/18 15:00 RPV

Sample Receipt Conditions:

- Sample(s) received with containers or preservation that are not valid for one or more analyses. Affected analyses are reported with the (P) qualifier.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 11/12/2018 11:43 am 8105424
STL_DW_Results Revision #1.7 Effective: 07/09/2014





8105424
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road
Lancaster, PA 17601

Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com

Sample Name: Wilson SD - High School - Upper House

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
1	Water Fountain - A-500 Hall	10/29	0802	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2
2	Water Fountain - E-400 Hall		0806	MA	1st Draw - Lead in Water	1		G	P	H	
3	Sink - Nurse's office		0808	MA	1st Draw - Lead in Water	1		G	P	H	
4	Sink - Cafeteria		0811	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y / N</u> Number of containers match number on COC? <u>Y / N</u> All containers in tact? <u>Y / N</u> Tests within holding times? <u>Y / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>09:10</u>	Temp °C: <u>4.50</u> Acceptable: <u>Y / N</u>				
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: <u>4.00</u> Acceptable: <u>Y / N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y / N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



8105424
Ryan F Knerr

TAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road

Lancaster, PA 17601

Contact Name: Mark Andrechik

Phone: 717-558-3008

Fax: _____

Email: labresults@ehcassociates.com

Act Name: Wilson SD - High School - Lower House

Address: _____

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
5	Stadium Concession Sink	10/29	0812	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2
6	Sink - locker room		0825	MA	1st Draw - Lead in Water	1		G	P	H	
7	Sink - Kitchen		0829	MA	1st Draw - Lead in Water	1		G	P	H	
8	Sink - outside main office		0831	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By:	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Tests within holding times? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By:	Date: <u>10-30-18</u> Time: <u>09:10</u>	Temp °C: <u>4.5°</u> Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N				
Relinquished By:	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: <u>4.0°</u> Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N				
Received in Lab By:	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road
Lancaster, PA 17601

Contact Name: Mark Andrechik

8105424
Ryan F Knerr

Phone: 717-656-3008

Fax: _____

Email: labresults@ehcassociates.com

Site Name: Wilson SD - Berkshire Heights

Address: _____

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	9 - Sink - Kitchen	10/29	0848	MA	1st Draw - Lead in Water	1		G	P	H	PH < 2
	10 - Fountain - Near Rm 4		0851	MA	1st Draw - Lead in Water	1		G	P	H	
	11 - Sink - boys bathroom basement		0853	MA	1st Draw - Lead in Water	1		G	P	H	
	12 - Fountain - Main Hallway		0857	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>0410</u>	Temp °C: <u>4.50</u> Acceptable: <u>Y/N</u>				
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>10:20</u>	Temp °C: <u>4.00</u> Acceptable: <u>Y/N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

8105424
Ryan F Knerr

Name: Wilson SD - Spring Ridge Elem

Address: 2502 Horseshoes Road

Phone: _____

Address: _____

Lancaster, PA 17601

Fax: _____

Contact Name: Mark Andrechik

Email: labresults@ehcassociates.com

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	13 - Sink - Kitchen	10/29	912	MA	1st Draw - Lead in Water	1		G	P	H	PH < 2
	14 - Sink - Faculty Room	↓	915	MA	1st Draw - Lead in Water	1		G	P	H	↓
	15 - Sink - Room 117		918	MA	1st Draw - Lead in Water	1		G	P	H	
	16 - Fountain - Near Nurse		922	MA	1st Draw - Lead in Water	1		G	P	H	↓

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>(Y) / N</u> Number of containers match number on COC? <u>(Y) / N</u> All containers in tact? <u>(Y) / N</u> Tests within holding times <u>(Y) / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-14</u> Time: <u>0810</u>	Temp °C: <u>4.5°C</u> Acceptable: <u>Y/N</u>				
Relinquished By: _____	Date: <u>10-30-14</u> Time: <u>11:20</u>	Temp °C: <u>4.0°C</u> Acceptable: <u>Y/N</u>				
Received in Lab By: _____	Date: <u>10-30-14</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



8105424
Ryan F Knerr

TAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road
Lancaster, PA 17601

Contact Name: Mark Andrechik

Phone: 717 555 0000

Fax: _____

Email: labresults@ehcassociates.com

Project Name: Wilson SD - Whitfield Elem

Address: _____

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	17-Sink - Kitchen	10/29	0929	MA	1st Draw - Lead in Water	1		G	P	H	pH < 7
	18-Fountain - Hall @ main office		0931	MA	1st Draw - Lead in Water	1		G	P	H	
	19-Fountain - Hall @ Bldg		0934	MA	1st Draw - Lead in Water	1		G	P	H	
	20-Sink - bathroom @ C120		937	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y / N</u> Number of containers match number on COC? <u>Y / N</u> All containers in tact? <u>Y / N</u> Tests within holding times? <u>Y / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>0910</u>	Temp °C: <u>4.5</u> Acceptable: <u>Y / N</u>				
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: <u>4.0</u> Acceptable: <u>Y / N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y / N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



8105424
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road
Lancaster, PA 17601

Contact Name: Mark Andrechik

Phone: _____

Fax: _____

Email: labresults@ehcassociates.com

Project Name: Wilson SD - Southern Middle School

Address: _____

Payment / P.O. Info: 008721-006

Comments: _____

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	21 - Sink - transportation bldg	10/19	1006	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2
	22 - Sink - Kitchen		1001	MA	1st Draw - Lead in Water	1		G	P	H	
	23 - Fountain - @ Gym		1014	MA	1st Draw - Lead in Water	1		G	P	H	
	24 - Sink - boys bathroom @ outdoor campus		1017	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>10/30</u> Time: <u>09:00</u>		Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times? <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>09:10</u>	Temp °C: <u>4.5°</u> Acceptable: <u>Y/N</u>				
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>15:20</u>	Temp °C: <u>4.0°</u> Acceptable: <u>Y/N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



TAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

8105424
Ryan F Knerr

Site Name: Wilson SD - Cornwall Terrace Elem.

Address: 2502 Horseshoes Road

Lancaster, PA 17601

Fax: _____

Address: _____

Contact Name: Mark Andrechik

Email: labresults@ehcassociates.com

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	25 - Fountain - @ Rm 102	10/29	1026	MA	1st Draw - Lead in Water	1		G	P	H	pH 7.2
	26 - Fountain - @ Rm 111	↓	1029	MA	1st Draw - Lead in Water	1		G	P	H	↓
	27 - Fountain @ Rm 132	↓	1032	MA	1st Draw - Lead in Water	1		G	P	H	↓
	28 - Sink - Nurse's office	↓	1036	MA	1st Draw - Lead in Water	1		G	P	H	↓

Relinquished By:	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y / N</u> Number of containers match number on COC? <u>Y / N</u> All containers in tact? <u>Y / N</u> Tests within holding times <u>Y / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By:	Date: <u>10-30-18</u> Time: <u>0810</u>	Temp °C: <u>4.5°</u> Acceptable: <u>Y / N</u>				
Relinquished By:	Date: <u>10-30-18</u> Time: <u>11:30</u>	Temp °C: <u>4.0°</u> Acceptable: <u>Y / N</u>				
Received in Lab By:	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y / N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



8105424
Ryan F. Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road

Lancaster, PA 17601

Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com

Project Name: Wilson SD - Shiloh Hills Elem

Address: _____

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	29 - Sink - Office	10/29	1054	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2
	30 - Sink - Rm 163	↓	1057	MA	1st Draw - Lead in Water	1		G	P	H	↓
	31 - Sink - Rm 101	↓	1101	MA	1st Draw - Lead in Water	1		G	P	H	↓
	32 - Sink - Kitchen	↓	1105	MA	1st Draw - Lead in Water	1		G	P	H	↓

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times? <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>05:10</u>	Temp °C: <u>4.5°C</u> Acceptable: <u>Y/N</u>				
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>10:20</u>	Temp °C: <u>4.0°C</u> Acceptable: <u>Y/N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



Chain of Custody Record

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC AssociatesAddress: 2502 Horseshoes RoadLancaster, PA 17601Contact Name: Mark Andrechik

8105424





Ryan F Knerr

Fax: _____

Email: labresults@ehcassociates.comName: Wilson SD - Green Valley ElemPayment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	33 - Sink - office bathroom	10/29	1123	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2 ↓ ✓
	34 - Sink - Rm 159	↓	1126	MA	1st Draw - Lead in Water	1		G	P	H	
	35 - Sink - Rm 111		1130	MA	1st Draw - Lead in Water	1		G	P	H	
	36 - Sink - Kitchen	↓	1133	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: 	Date: <u>10/30/18</u> Time: <u>0900</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: 	Date: <u>10-30-18</u> Time: <u>09:10</u>	Temp °C: <u>4.5°</u> Acceptable: <u>Y/N</u>	Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Relinquished By: 	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: <u>4.0°</u> Acceptable: <u>Y/N</u>				
Received in Lab By: 	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



8105424
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoes Road
Lancaster, PA 17601

Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com

ect Name: Wilson SD - West Middle School

ress: _____

Payment / P.O. Info: 008721-006

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	37 - Sink - Kitchen	10/29	1139	MA	1st Draw - Lead in Water	1		G	P	H	PHC2
	38 - Fountain - @ SLI 120		1141	MA	1st Draw - Lead in Water	1		G	P	H	
	39 - Sink @ Nurse's		1143	MA	1st Draw - Lead in Water	1		G	P	H	
	40 - Fountain @ SLI 138		1147	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>10/30</u> Time: <u>0500</u>		Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>10-30-18</u> Time: <u>08:10</u>	Temp °C: <u>3.9°</u> Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: <u>3.8°</u> Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N			
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>1120</u>	Temp °C: _____ Acceptable: <input type="checkbox"/> Y / <input type="checkbox"/> N	Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N			
			40 mL VOA vials free of headspace? <input type="checkbox"/> Y / <input type="checkbox"/> N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



Chain of Custody

TAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates
Address: 2502 Horseshoes Road
Lancaster, PA 17601Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com8105424
Ryan F KnerrClient Name: Wilson SD - Lower Heidelberg

Address: _____

Payment / P.O. Info: 008721-006

Comments: _____

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	41- Fountain - South end	10/29	1208	MA	1st Draw - Lead in Water	1		G	P	H	pH < 2 ↓
	42- Sink - Kitchen		1211	MA	1st Draw - Lead in Water	1		G	P	H	
	43- Sink - Office		1213	MA	1st Draw - Lead in Water	1		G	P	H	
	44- Sink - Janitor's closet		1217	MA	1st Draw - Lead in Water	1		G	P	H	
					*preserved 2mL of HNO ₃ pH < 2 USE 10-30-18						

Relinquished By: _____	Date: <u>10/30</u> Time: <u>5:00</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: _____	Date: <u>10-30-18</u> Time: <u>07:00</u>	Temp °C: <u>4.50</u> Acceptable: <u>Y/N</u>	Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Relinquished By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: <u>4.00</u> Acceptable: <u>Y/N</u>				
Received in Lab By: _____	Date: <u>10-30-18</u> Time: <u>11:20</u>	Temp °C: _____ Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.